

# Power-to-Gas: Analysis of potential decarbonization of Spanish electrical system in long-term prospective

Pilar Lisbona <sup>a\*</sup>, Guido Francesco Frate <sup>b</sup>, Manuel Bailera <sup>c</sup>, Umberto Desideri <sup>b</sup>

<sup>a</sup> Escuela de Ingeniería de la Industria Forestal, Agronómica y de la Bioenergía, Universidad de Valladolid. Campus Universitario Duques de Soria, 42004, Soria, Spain.

<sup>b</sup> Department of Energy, Systems, Territory and Constructions. Università di Pisa. Largo Lucio Lazzarino 1, polo A, 56122 Pisa, Italy.

<sup>c</sup> Escuela de Ingeniería y Arquitectura. Universidad de Zaragoza, Campus Río Ebro, María de Luna 3, 50018, Zaragoza, Spain.

## Abstract

Climate targets set by international organizations require the implementation of innovative technologies that ensure the decarbonization of energy sector. It may be partially achieved through a large penetration of Renewable Energy Sources. Massive energy storage is essential to handle excess electricity associated to RES and Power-to-Gas represents a promising option to chemically convert electricity surplus into energy carriers that may attend demands substituting fossil fuels. Aiming to avoid the influence of policies and market implications, this study approaches the decarbonization of Spanish system through the analysis of technical potential of RES. Several scenarios with different shares of RES are defined to cover a number of levels of energy demand. First, required wind and photovoltaic power has been estimated together with the required sizes of PtG to completely decarbonize electrical generation and industrial CHP. These scenarios may be reached by installing RES capacities below the technical potential coupled with PtG capacities between 80 and 90 GW. The stored energy amounts to 17% of total primary energy consumption. Secondly, scenarios are modified to consider denuclearization of electrical system. Required installed RES power still does not surpass the technical potential but become extremely high and the economic feasibility should be further analysed.

**Keywords.** Power-to-gas, Energy storage, Spanish scenario, Synthetic Natural Gas

## 1. Introduction

The current European energy policy was established in 2009 through the European Renewable Energy Directive (RED 2009/28/EC) [1], which sets a minimum of 20% of renewable share in the European final energy consumption by 2020 and a 10% of renewable penetration in transport sector. The Commission updated these figures on November 2016 with a new proposal to ensure 27% renewables in the final energy consumption in the EU by 2030 [2].


---

\* Corresponding author

35 Each country should fulfill individual targets adapted to their different resources and the features  
36 of its own energy market. In the case of Spain, Spanish National Renewable Energy Action Plan  
37 (NREAP) gathered the 2011-2020 road map to meet the requirements of the Renewable Energy  
38 Directive. Spanish Royal Decree 661/2007 regulates electrical energy production under special  
39 regimes and provided for the drafting of a Renewable Energy Plan for implementation during the  
40 period 2011-2020 (REP 2011-2020) [3].

41 All Member States but the Netherlands showed an average 2013/2014 RES share equal or higher  
42 than their corresponding indicative trajectory of the European Directive. In 2015, European RES  
43 share was estimated to be around 16.4% of gross final energy consumption, while the Directive  
44 had projected only 13.8%. Thus, Spain fulfilled its indicative European RED trajectory with a  
45 RES share of 16.2% in 2014 and 15.6% in 2015 [4]. However, larger penetration of renewables  
46 will be required in the next decades to achieve the global figure (20% in 2020 or 27% in 2030)  
47 and further work must be done to increase the current 0.5% of biofuels penetration in transport  
48 up to the Directive target [5].

49 The high shares of renewable sources in the electricity production system will lead to fluctuating  
50 periods of surplus power that could limit the operational predictability and flexibility of the  
51 electricity network [6] which will be only partially mitigated through Power to Heat and electrical  
52 vehicle deployment [7,8]. Thus, energy storage technologies are imperative in future electricity  
53 systems to manage renewable intermittent power. Current storage techniques (pumped  
54 hydroelectric storage, compressed air energy storage, flywheels, electrochemical storage, thermal  
55 energy storage) present limited storage potentials for large scale applications due special location  
56 requirements, short storage periods, slow discharge times or low energy storage densities [6].  
57 Hydrogen energy storage (HES) overcomes these issues but it lacks a proper distribution  
58 infrastructure and transformation technology. Besides, HES implies additional handling safety  
59 measures. To avoid the mentioned limitations, Power-to-Gas energy storage has been pointed out  
60 in the last years as a very promising solution, which converts mixtures of renewable H<sub>2</sub> and CO<sub>2</sub>  
61 into synthetic natural gas (SNG) [9]. This final energy carrier can be easily stored and distributed  
62 through the existing gas grid and transformed into electricity or heat in conventional equipment  
63 with high efficiency, durability and limited investment costs (Figure 1) [10].



64 **Natural gas network**

65 *Figure 1. Scheme of the energy system with PtG*

66 The potential increase of installed capacity of non-dispatchable energy sources in Spain is  
 67 extremely high. Installed wind power in 2016 was 22.8 GW, while prospective studies established  
 68 a feasible installed capacity of 52.5 GW in 2030 [11] and a maximum potential in the country  
 69 between 332-393 GW [12–14]. Similarly, photovoltaic installed capacity in 2016 was around 4.4  
 70 GW, although several reports show there is room to install up to 66.5 GW [15]. Moreover, several  
 71 nuclear plants are near to finish their lifetime in Spain, so the nuclear debate is currently open.  
 72 Both situations clearly foster the idea of a Spanish electrical system mostly based on renewable  
 73 sources, thus promoting the decarbonization and the energetic independence. Emission factors of  
 74 Spanish electricity producers ranges from 0 to 360 gCO<sub>2</sub>/kWh in 2016 [16] with an average value  
 75 of the electrical mix of 306 gCO<sub>2</sub>/kWh in 2016 [17] which is still quite far from the targets of  
 76 specific emissions established for 2020 (207-218 gCO<sub>2</sub>/kWh) [18]. Regarding the energy  
 77 dependence of the country, external dependency in 2016 represented 72.3% of gross primary  
 78 energy versus the average value in Europe set in 50% [19].

79 Therefore, the development of improved energy storage technologies is especially relevant to  
 80 exploit the greatest amount of the renewable potential in the country without introducing  
 81 instabilities in the future renewable electric system.

82 The objective of this study is to quantify the renewable power and Power-to-Gas capacities  
 83 required to decarbonize and denuclearize the energy mix of the Spanish electricity system under  
 84 different energy scenarios. The technology used for electric power production varies in each  
 85 scenario to increase the decarbonization and denuclearization of the system.

86 **2. Energy scenarios: Scope and limitations of the study**

87 In literature, several studies quantify Power to Gas potential under future scenarios of national  
 88 energy systems in which RES installed capacity is high enough to frequently lead to electricity  
 89 surplus situations [20–23]. However, when these scenarios are tried to be foreseen, the strong  
 90 uncertainty coming from economics, regulatory policies and technology evolution leads to  
 91 disputable results. Thus, the attempt of defining an accurate estimation of future installed  
 92 capacities such as those annually predicted by international organizations [24] mainly based on  
 93 economic, political and technologic situation is discarded in this study, and a similar approach to  
 94 that followed by Guandalini *et al.* [25] and Colbertaldo *et al.* [26] is applied instead.

95 Guandalini *et al.* looked for the upper technical limit of installed power for each non-dispatchable  
 96 technology since long-term energy systems will ideally make the most from their resources, and  
 97 therefore will tend to reach the maximum installation potential. Considering geographical and  
 98 climate constraints together with the development of the state of the art in technology, the  
 99 maximum reasonable power capacity for a given region may be estimated (Table 1) [12,13,15].  
 100 Wind and photovoltaic are those non-dispatchable technologies with larger growing potential and,  
 101 therefore, those considered to define the scenarios under study. The possibility of decarbonizing  
 102 and denuclearizing the Spanish electrical mix under different technological scenarios through the  
 103 penetration of massive wind and photovoltaic energy sources is assessed. Then, results of wind  
 104 and PV installed capacities are compared with the technical maximum as a measure of its  
 105 feasibility.

106 *Table 1. Technical potential in Spain from different studies*

Technology	Technical potential [GW]	References
Wind	392.95	[12]
	340.00	[13]
	151.00 – 332.00	[14]
Photovoltaic	66.51	[15]

107

108

109 Electric demand is assumed to keep constant and similar to the current situation. Although the  
 110 electrical demand has slightly grown in the last years in Spain (annual growth of 0.7% in 2016  
 111 and 1.2% in 2017 [27]), the trend in European countries is the conservation or slight decrease of

112 demand as a consequence of energy efficiency improvements and limited economic growth. As  
113 an example, total net electricity generation in the EU-28 in 2015 was 4.5 % lower than its relative  
114 peak of 2008 [28]. Therefore, it must be kept in mind that the results obtained from this study will  
115 be valid in case this assumption is fulfilled.

116 Thus, this study is conducted using the electric demand data and hourly distribution corresponding  
117 to 2016 (last reported data by Spanish transmission system operator) which is considered the  
118 reference year [17]. This demand is covered through a combination of base power (CHP and  
119 nuclear power), non-dispatchable power (small hydroelectric, geothermal, concentrated solar,  
120 wind and photovoltaic) and back-up technologies.

### 121 ***2.1 Current Spanish scenario and selected technical potential for wind and PV power***

122 Firstly, current situation of the Spanish electrical mix must be analysed to better understand the  
123 motivation and justification of some of the assumptions included in this analysis. The main  
124 technologies included in the mix have been divided (i) base load (nuclear and cogeneration), (ii)  
125 non-dispatchable RES (hydro, geothermal, concentrated solar, wind, photovoltaic) and (iii) back-  
126 up technologies (fossil fuels and dispatchable technologies such as biomass power plants).

127 Regarding base power, there are not planned projects for increasing current nuclear capacity in  
128 the mid-term (7.8 GW). The seven existing plants commissioned between 1983 and 1988  
129 still participate in the energy market with capacity factors around 90%. All these plants  
130 should shut down in the near future but given their high share in the energy mix they will  
131 probably get granted with 10-year lifetime extensions by favorable reports from the  
132 authorities [29,30]. Thus, we consider a constant nuclear power capacity in the study.

133 The decarbonization of industry also represents a hot topic in Europe and the implications of  
134 changes in CHP for future EU electricity demand will be relevant [31]. CHP operates at full load  
135 most of the time and cannot be regulated, since over 600 companies (mostly chemical, paper, and  
136 food industries) produce 50% of CHP power production. Because of the 2008 financial crisis, the  
137 production was slowed down, and therefore the Spanish CHP association expects that installed  
138 capacity remains constant at 6.7 GW for the next years [32]. So, we consider that CHP installed  
139 capacity, operating hours and distribution throughout the year keep unchanged from 2016 data.  
140 This trend has been also checked with accumulated data in 2017 [17].

141 With regard to non-dispatchable technologies, hydropower is a well consolidated technology in  
142 Spain with 20.6 GW of installed capacity. This value is already close to its maximum potential  
143 estimated to be near 33 GW [33]. Large projects are not expected to occur in mid-term, while  
144 forecast indicates a moderate increase of installed power by repowering existing plants or  
145 powering irrigating dumps. Thus, hydropower may be considered constant in our scenarios.

146 Geothermal resource is scarce in Spain and so do its share in the energy mix. Conservative  
147 prospective studies account only for near 83 MW of new installation by 2020 [13], therefore we  
148 may assume that geothermal capacity keeps constant in the mid-term also.

149 Regarding concentrated solar power, no new projects are expected since incentives have been cut.  
150 So, even though the national renewable energy action plan (NREAP) envisaged CSP capacity of  
151 5 GW by 2020 [34], we do not consider any growth in the installed capacity.

152 As stated, base load and part of non-dispatchable renewable technologies are not expected to  
153 significantly grow and their contribution will be much less important in the share of electric  
154 generation than wind or photovoltaic contribution. As a simplification, the decarbonization  
155 process - and the potential denuclearization - of electricity production is assumed to be conducted  
156 by increasing wind and photovoltaic installed power, since they represent the main renewable  
157 sources in Spain and have the greatest growth potential (Table 1).

158 The maximum potential deployment of wind power in Spain has been valued between 151-393  
159 GW [12–14]. The most reliable model was that developed in the framework of RESHAPE project  
160 [12] which considers two main factors of influence in the estimation of available wind energy  
161 potential: (i) the local wind regime influencing the energy yield of a turbine, and (ii) the land area  
162 available for construction of wind turbines which determines the total available wind capacity  
163 potential. Thus, the selected maximum potential considered in this study is 393 GW which is still  
164 far from the current installed capacity of 22.5 GW.

165 When dealing with photovoltaic power, the estimation of the technical potential becomes quite  
166 complex, since the available surface depends on many variables. A reduced number of  
167 comprehensive studies have been published so far [13], from which the most reliable data are  
168 those of IEA's reports [15]. Based on the estimated available surfaces on buildings and ground  
169 (617 km<sup>2</sup>), the technical potential results in about 66.51 GW of installed photovoltaic systems.

170 Finally, the back-up power required to cover electrical demand beyond base load and non-  
171 dispatchable sources includes fossil conventional thermal plants (coal and gas) and renewable  
172 energy sources such as biomass or biogas and waste. Current installed capacity of controllable  
173 and adjustable back-up technologies rises up to 91 GW: 46 GW coal thermal plants, 39 GW  
174 natural gas combined cycles, around 2.5 GW biomass and biogas facilities and 3.5 GW waste  
175 facilities [27].

176 The increase of wind and photovoltaic power capacity aims to replace current fossil fuels-based  
177 backup technologies (coal and natural gas, 85 GW), partially decarbonizing the energy mix. This  
178 decarbonization is supported by the utilization of synthetic natural gas produced by means of

179 Power to Gas facilities which absorb surplus electricity from non-dispatchable RES and manage  
 180 the availability of this energy later in time.

181 **2.2 Proposed scenarios**

182 After providing basic information on the electrical mix trends and situation, the three possible  
 183 scenarios that will be analyzed in this work are defined in the following paragraphs. The first  
 184 studied framework denoted as *Scenario 1* (Table 2) quantifies the growth of wind and PV installed  
 185 capacity and the required Power-to-Gas capacity needed to completely decarbonize the backup  
 186 power system of Spain. The back-up technologies, Gas Turbines (GT) and Combined Cycles (CC)  
 187 required under this scenario are fed by synthetic fuel (H<sub>2</sub> or CH<sub>4</sub>) produced from the surplus  
 188 renewable electricity through PtG facilities.

189 In a second scenario (*Scenario 2*), decarbonization is extended to also cover the CHP technology.  
 190 Under this scenario, conventional CHP is considered to be fed by renewable synthetic fuel  
 191 generated by PtG. It is assumed that CHP technologies will present the same hourly production  
 192 patterns since they are associated to socioeconomic factors which are expected to remain constant.  
 193 Thus, the required increase of wind, photovoltaic and PtG capacities are quantified in order to  
 194 have enough available electricity excess to fulfill both backup and CHP's fuel requirements. In  
 195 these two first scenarios, four cases are evaluated (Table 2). Each of these cases accounts for one  
 196 specific synthetic fuel and one single transformation technology.

197 A third scenario (*Scenario 3*) is analyzed, in which backup and CHP conventional technologies  
 198 are substituted by fuel cells fueled with H<sub>2</sub> from surplus renewable electricity. The growth of  
 199 Power-to-Gas technology will be significantly different from *Scenario 1* and *2* given the greater  
 200 efficiency of the reconversion technology. Besides, the heat to electricity production ratio of fuel  
 201 cells highly differ from conventional CHP technologies.

202 *Table 2. Scenarios under study to decarbonize the electrical Spanish system.*

	<b>Scenario 1</b>	<b>Scenario 2</b>	<b>Scenario 3</b>
<b>Electrical demand</b>			
Reference year 2016	Constant demand & pattern	Constant demand & pattern	Constant demand & pattern
<b>Base load</b>			
CHP <sup>1</sup>	Conventional based on fossil fuel	Conventional based on PtG	Fuel Cell based on PtG
Nuclear <sup>2</sup>	Conventional	Conventional	Conventional
<b>Non-dispatchable</b>			
Wind	Growing capacity	Growing capacity	Growing capacity
PV	Growing capacity	Growing capacity	Growing capacity
CSP	Constant capacity	Constant capacity	Constant capacity
Hydroelectric power	Constant capacity	Constant capacity	Constant capacity
Geothermal power	Constant capacity	Constant capacity	Constant capacity
<b>Backup power (based on PtG)</b>			
GT based on H <sub>2</sub>	Case A	Case A	-
CCGT based on H <sub>2</sub>	Case B	Case B	-
GT based on CH <sub>4</sub>	Case C	Case C	-

CCGT based on CH4	Case D	Case D	-
Fuel Cell based on H2	-	-	Case E

203  
204

<sup>1</sup> The amount of heat provided by CHP is considered constant.

<sup>2</sup> Nuclear installed capacity and operation factor are considered constant.

205 Additionally, the study assesses the possibility of denuclearizing the energy system, under the  
206 framework of these three scenarios. The energy produced by nuclear power would be replaced  
207 also by wind, PV and renewable backup, so the required installed capacity drastically growth.  
208 The closer to the technical upper limit, the more limited feasibility of deployment for each case.


### 209 3. Methodology of PtG capacity calculation

210 Once the target of each scenario and the conditions of the considered cases have been defined,  
211 the steps which have been followed to obtain the results are presented in this section. Figure 2  
212 illustrate the flowchart with initial data sources (elliptic boxes), the data management (rounded  
213 boxes), the final calculated variable (square boxes) and the conditions for scenarios and cases  
214 (rhomboid boxes).

215 The surplus electricity was defined and calculated for previous years with historical data.  
216 Obtained values show similar requirements of back-up electricity and surplus energy for similar  
217 installed capacities. Thus, the hourly distribution of the operation of different generation  
218 technologies along the year leads to similar behaviors when the annual timeframe is considered.  
219 This will be used to establish a reference hourly distribution pattern for wind and photovoltaic  
220 technology which will be used in the estimation of surplus energy in future situations. Hourly  
221 demand, base power production and CSP/hydroelectric/geothermal production are directly taken  
222 from 2016 data.

223 Only wind and photovoltaic power are considered to grow in future scenarios to decarbonize the  
224 system. So, first we calculate the wind and photovoltaic production by using the hourly  
225 distribution derived from 2016 data and a given installed capacity. Then, the balance of the  
226 electricity system is computed to estimate surplus electricity periods and back-up requirements at  
227 every hour in prospective scenarios. The method used to derive the optimal PtG capacity for a  
228 specific scenario is explained through the use of the duration curve of the surplus electricity.

229 Once PtG is sized, the stored energy is analysed to determine the potential to match deficiency  
230 situations according to the selected scenario of decarbonization, back-up technology used, and  
231 synthetic fuel produced. Whenever a mismatch exists, the wind and PV installed capacity are  
232 modified (iterative calculations).



233

234 Figure 2. Flowchart of the methodology used for calculation of PtG capacity under proposed scenarios

### 235 3.1. Balance of energy definition

236 The energy balance is defined in Eq. 1 to determine whether an electricity system with high  
 237 renewable sources penetration will require the operation of dispatchable electricity conventional  
 238 sources to complete the coverage of the demand or the operation of energy storage technologies.

$$239 \quad BE_t = \sum E_{ND,t} + \sum E_{BL,t} - D_t \quad (\text{Eq.1})$$

240 This energy balance definition,  $BE_t$ , compares the production from base-load energy sources,  
 241  $\sum E_{BL,t}$ , and non-dispatchable energy sources,  $\sum E_{ND,t}$ , with the hourly electrical demand,  $D_t$ .  
 242 Between 2014 and 2016, annual Spanish electrical demand remained almost constant and ranged  
 243 243-249 TWh/year. The non-dispatchable sources will include different climate-dependent  
 244 technologies. To calculate the potential surplus of energy those technologies which are included  
 245 in the base load must be also considered. In Spain, the base load consists of electrical generation  
 246 from CHP which is related to industrial production following its own patterns and nuclear

247 generation. Nuclear operates over 7200 hours per year providing an average of 22.2% of total  
248 electricity production in 2016 [17].

249 The back-up power of the system will be required to complete the coverage of the electrical  
250 demand whenever this variable takes a negative value, namely  $BE^-$ . The back-up technologies  
251 include coal, gas and biomass or waste traditional thermal power plants. In those periods in which  
252 base load and non-dispatchable generation surpass the total demand, the balance becomes positive  
253  $BE^+$ , and surplus electricity may be directed. Power to Gas is the only storage technology taken  
254 into consideration in this study since its order of magnitude (GWh-scale) and the country-level  
255 analysis leave apart from the discussion the low energy capacity equipment. Other large-scale  
256 storage equipment, such as hydro pumping, are also out of the scope of the study since they have  
257 mostly achieved their maximum capacity.

258 From data provided by Spanish Electrical Grid (*Red Eléctrica Española*) in its Transparency  
259 Report [17] and the definition of energy balance from Eq. 1, the hourly energy balance has been  
260 calculated for the three set of available data (2014, 2015 and 2016) to detect deviations. An  
261 analysis of data between 2014 and 2016 [17] concluded that a statistical treatment cannot be  
262 applied since most relevant information for our study which is related to the peak situations would  
263 be eliminated. It can be seen in Table 3 that annual values of back-up requirement,  $|BE^-|$ , and  
264 excess electricity,  $BE^+$ , present the same order of magnitude in the past years. Since energy  
265 demand and production are influenced by several different factors, it is natural to observe a certain  
266 degree of fluctuations, like those highlighted in Table 3. From this perspective could be very  
267 challenging to predict the exact amount of required PtG capacity since the forecasting of the exact  
268 RES production patterns for the forthcoming years is extremely difficult.

269 Current Spanish energy scenarios do not present surplus energy large enough to propose the  
270 installation of PtG technologies as a solution to decarbonize any sector. The annual excess varies  
271 from 160-560 GWh distributed along the whole territory with a peak power between 2.7-5.6 GW  
272 [17]. These current figures do not make attractive the massive deployment of this technology, but  
273 the energy system continuously evolves, and the future energy scenario is expected be extremely  
274 different.

275 *Table 3. Aggregated values of back-up requirements and surplus electricity in 2014, 2015 and 2016 (Spain).*

	$ BE^- $ [TWh/y]	$BE^+$ [TWh/y]
<b>2014</b>	65,88	0,36
<b>2015</b>	81,92	0,16
<b>2016</b>	75,99	0,56

276

277 In this work, potential scenarios with a higher penetration of RES which may make PtG attractive  
278 will be defined by means of the procedure described in the following paragraphs. Once the  
279 required variables are assumed or estimated under these new scenarios the surplus energy will be  
280 calculated as described in this section, Equation 1.

### 281 **3.2. Hourly distribution of non-dispatchable RES production**

282 As shown in Figure 2, one of the first steps is the determination of the hourly distribution of wind  
283 and photovoltaic sources. This distribution will be used in the calculation of their electricity  
284 production along the year,  $E_{i,t}$ , in the different scenarios.

285 The hourly distribution of electric demand throughout the year,  $D_t$ , is considered to follow a  
286 constant pattern. Also, constant patterns of climate-dependent renewable energy sources are  
287 expected along the years. Therefore, the hourly distribution of wind or PV energy generation  
288 along the year,  $E_{i,t}$ , in future scenarios may be linearly scaled. In this study, the reference hourly  
289 pattern is assumed the same than year 2016, and then the generation is scaled up following Eq. 2,  
290 where  $C_i$  is the proposed installed capacity of the model [25].

$$291 \quad E_{i,t} = \frac{E_{i,t}^0}{C_i^0} \cdot C_i \quad (\text{Eq.2})$$

292 The  $E_{i,t}^0/C_i^0$  factor represents the hourly pattern, i.e., the equivalent operating hours of technology  
293  $i$ , at time  $t$ , for a selected reference year. It is known that wind power production behaves as a  
294 chaotic system, and therefore the instantaneous values of  $E_{i,t}^0/C_i^0$  highly differ from one year to  
295 another. Nevertheless, the aggregated values of wind power production in previous years (2014,  
296 2015 and 2016) presented in section 3.1 give similar global outputs when the whole year is  
297 accounted. This assumption is essential to scale-up the hourly distribution along the year of RES  
298 generation. Therefore, it is considered that 2016 pattern is representative and the distribution and  
299 number of hours of operation have been calculated through equation 2, taking as reference year  
300 2016.

301 This approach is only focused on photovoltaic and wind production. This analysis is based on  
302 data of hourly production and load profiles available from transmission system operator websites,  
303 ESIOS – Red Eléctrica Española (Transparency reports, European Regulation 1228/2013) [17].

### 304 **3.3. Variation parameters to modify installed non-dispatchable RES power**

305 Besides the distribution of operating hours along the year ( $E_{i,t}^0/C_i^0$  section 3.2), to estimate the  
306 electricity production of wind and solar sources,  $E_{i,t}$ , their installed capacity in the analysed  
307 scenarios,  $C_i$ , must be addressed. Most of the existing studies are focused on market evolution  
308 and affected by economic and regulation. However, a more global analysis of RES technical  
309 potential should not take into account these aspects, but only limitations due to available resources

310 and environment safeguard. A review of available data in literature considering the technical  
 311 potential is summarized in Table 2. From these studies, values considered as more reliable are  
 312 392.95 GW for wind power [12] and 66.51 GW for photovoltaic installed power [15]. These  
 313 figures are used in the following as maximum installed capacity.

314 To express the installed capacity of wind and photovoltaic under each scenario, two new variables  
 315 are defined,  $\gamma_w$  and  $\gamma_{pv}$ , as presented in (Eq. 3):

$$316 \quad \begin{cases} \gamma_w = \frac{C_w - C_w^0}{C_w^{max} - C_w^0} \\ \gamma_{pv} = \frac{C_{pv} - C_{pv}^0}{C_{pv}^{max} - C_{pv}^0} \end{cases} \quad (\text{Eq. 3})$$

317 These equations compare the productive installed capacity considered in our study,  $C_i$ , with  
 318 maximum achievable installed capacity,  $C_i^{max}$ , and current productive capacity,  $C_i^0$ . In this way,  
 319 the percentage of increase over the current installed capacity (reference year, 2016) with respect  
 320 to the maximum possible increase of installed capacity is defined. The modified capacity can now  
 321 be calculated from (Eq.3) as expressed in (Eq.4):

$$322 \quad C_w = C_w^0 \left[ 1 + \frac{(C_w^{max} - C_w^0)\gamma_w}{C_w^0} \right]$$

$$323 \quad C_{pv} = C_{pv}^0 \left[ 1 + \frac{(C_{pv}^{max} - C_{pv}^0)\gamma_{pv}}{C_{pv}^0} \right] \quad (\text{Eq. 4})$$

### 324 **3.4. Surplus energy estimation**

325 The terms of (Eq.1),  $E_{i,t}$ , correspond to existing values in the case of historical calculations. When  
 326 new scenarios are to be defined these terms must be estimated based on (i) existing values  
 327 (reference year) and on (ii) prospective installed power. As presented in section 3.2, current values  
 328 are used to define electric demand and the distribution of operating hours of non-dispatchable  
 329 technologies. Prospective installed power will be estimated depending on the specific case to  
 330 study as presented in section 3.3.

331 The installed power capacity of wind and photovoltaic sources in the scenario under study is  
 332 represented by  $C_i$  and its value will be always below the technical potential. The model, through  
 333 Eq. 2, assumes a constant distribution of the equivalent operating hours for the technologies. The  
 334 reference value of installed capacity and the reference generation distribution are considered to  
 335 be those of 2016.


336 The negative values of energy balance will determine the requirements of back-up power capacity  
 337 in the system while the positive values of the surplus energy indicates the amount of annual energy  
 338 available for storage. As seen back-up power is not *a priori* defined in the model but calculated

339 as hourly back-up amount of energy. In this study focused on the decarbonization of electricity  
 340 production, considered back-up technologies will be those fed by hydrogen or synthetic natural  
 341 gas from PtG and based in RES. For the sake of simplicity and given the small share of biomass  
 342 and biogas fed power plants, the back-up technology has been considered homogeneous for each  
 343 studied scenario: gas turbine thermal plants, combined cycles thermal plants and fuel cells.

344 The surplus energy may be stored as valuable fuel gas (hydrogen or synthetic natural gas) in the  
 345 natural gas grid and be used in the proper moment and location to provide electricity or to cover  
 346 thermal demand, Figure 1.

### 347 **3.5. Duration curve and optimal PtG installed power**

348 Once the hourly availability of surplus energy is determined through the calculation of  $BE_t$  (Eq.1),  
 349 the optimal PtG capacity must be defined. To determine the recommended installed capacity of  
 350 PtG under each scenario the load duration curve is built and the PtG capacity will be obtained by  
 351 choosing a minimum number of 1000 operating hours in x-axis, Figure 3.



352

353 *Figure 3. Duration curve with the energy available for the PtG (medium grey) and the dumped energy (dark grey)*

354 The hourly energy surplus ( $BE_t^+$ ) is sorted in descending order to obtain the duration curve. On  
 355 the duration curve, choosing the amount of hour at which the PtG must be able to work at full  
 356 capacity, the PtG nominal power to be installed can be calculated. As reported in Figure 3, the  
 357 choice of  $h_{nom}$  determines not only the PtG installed capacity, but also the amount of energy that  
 358 can be harvested (grey-shaded area) and the energy that has to be dumped (dark grey-shaded  
 359 area).

### 360 **3.6. Renewable fuel production and back-up coverage calculation**

361 Once the PtG capacity is obtained from the duration curve of surplus energy, the amount of energy  
 362 stored as hydrogen or methane and the electricity produced from these synthetic renewable fuels  
 363 using three different technologies gas turbine cycles, combined cycles and fuel cells may be  
 364 calculated.

365 The amount of surplus energy stored as H<sub>2</sub> (Eq. 5) or CH<sub>4</sub> (Eq. 6) can be calculated from the grey-  
 366 shaded area in Figure 3, by multiplying such area which corresponds to the electricity that can be  
 367 handled by the PtG system by the efficiency of electrolyzers and the efficiency of methanation  
 368 process.

$$369 \quad E_{st}^{H_2} = (C_{PtG} \cdot h_{nom} + \sum_{\tau=h_{nom}}^{8760} BE_t^+) \cdot \eta_{H_2} \quad (\text{Eq.5})$$

$$370 \quad E_{st}^{CH_4} = E_{st}^{H_2} \cdot \eta_{CH_4} \quad (\text{Eq.6})$$

371 The energy available to storage is calculated through the installed PtG capacity, the hours  
 372 operating at nominal load and the positive values of surplus energy. In this study, alkaline  
 373 electrolyzer with efficiencies around 70% are considered [35] and the average efficiency of  
 374 methanation process found in literature is 80% [9,36,37]. Depending on the case of study (Table  
 375 2), (Eq. 5) or (Eq. 6) should be used.

### 376 **3.7. Determination of RES installed capacities**

377 Calculations presented in sections 3.2 to 3.6 are carried out for several production mix  
 378 combinations where wind and photovoltaic power are gradually increased as described through  
 379 equations (Eq. 3) and (Eq. 4). However, the target of the study is the determination of the new  
 380 installed capacity of wind and photovoltaic power required to fulfil the conditions established for  
 381 each scenario: (i) coverage of back-up by conventional technologies, (ii) coverage of back-up and  
 382 CHP by conventional technologies and (iii) coverage of back-up and CHP by fuel cell technology.

#### 383 Scenario 1

384 The target in *Scenario 1 (SC1)* is to assess the amount of photovoltaic and wind power additional  
 385 capacity that must be installed to cover the demand that is not instantaneously covered by based  
 386 load and non-dispatchable RES technologies without resorting to traditional fossil-fuel plants.  
 387 Negative values of energy balance,  $BE^-$ , show these periods in which electrical demand is not  
 388 covered by base load and non-dispatchable RES.

389 A new variable, which discriminate whether the decarbonation condition defined for each  
 390 scenario is fulfilled or not, is defined through equation (Eq. 7).

$$391 \quad \phi_j^{fuel} \Big|_{SC1} = E_{st}^{fuel} - \frac{\sum_{t=1}^{8760} |BE_t^-|}{\eta_j} \quad (\text{Eq. 7})$$

392

393 This variable will provide different results depending on the gaseous synthetic fuel considered  
 394 (*fuel*: H<sub>2</sub> or CH<sub>4</sub>) and the technology chosen to convert the gas fuel back into electricity (*j*: GT or  
 395 CCGT).

396 When  $\Phi$  is equal to zero in *Scenario 1*, the energy stored as synthetic fuel is able to perfectly  
 397 cover on an annual basis the electrical back-up needs of the system. Conversely, negative values  
 398 of  $\Phi$  indicate that the chosen combination of wind and photovoltaic installed capacities does not  
 399 originate a suitable surplus energy pattern and a PtG capacity which are able to make the back-up  
 400 system independent from conventional production plants. Finally, the situations in which positive  
 401 values  $\Phi$  are found correspond to those in which the RES production, jointly with the PtG, stores  
 402 more energy than the needed to cover back-up power.

### 403 Scenario 2

404 The target in this scenario (*SC2*) is to define the installed capacities of wind and photovoltaic  
 405 power required to completely decarbonize the electrical mix. Synthetic fuel produced by PtG from  
 406 surplus energy will be used to cover the back-up requirements and the CHP power installed in the  
 407 country.

408 Thus, the only difference in the calculation of  $\Phi$  for this second scenario will be the consideration  
 409 of CHP installed capacity which is assumed to remain constant in future situations. Since chemical  
 410 energy that power the CHP will be taken from the energy stored by the PtG as hydrogen or  
 411 methane, the equation (Eq.7) must be modified as follows (Eq.8):

$$412 \quad \phi_j^{fuel} \Big|_{SC2} = E_{st}^{fuel} - \left( \frac{\sum_{t=1}^{8760} |BE_t^-|}{\eta_j} + \frac{\sum_{t=1}^{8760} E_{CHP}}{\eta_{el}^{CHP}} \right) \quad (\text{Eq. 8})$$

413 The used fuel can be either H<sub>2</sub> or CH<sub>4</sub> and the used technology to reconvert gas fuel into electricity  
 414 can be gas turbine or combined cycle. The interpretation of the values obtained for  $\Phi$  is the same  
 415 presented in the previous subsection.

### 416 Scenario 3

417 The target in *Scenario 3* (*SC3*) is the same of *SC2*; to cover back-up generation and CHP electric  
 418 production without fossil-fuels. Therefore, the criteria and equation used to determine the  
 419 installed capacity of wind and photovoltaic (Eq. 8) to cover both back-up and CHP with renewable  
 420 synthetic gas.

421 The difference resides in the technologies used to generate back the electricity. *Scenario 3*  
 422 considers that fuel cell technologies are used in both back-up technologies and CHP. In the case  
 423 of back-up fuel cells technologies, this modification affects to the second term in equation (Eq.  
 424 8) through the efficiency in the denominator. The value of conversion efficiency of fuel cell

425 systems is accounted to be 0.6 which is slightly lower than nominal values to consider the effect  
426 of part load operation.

427 With regard to fuel cell technology applied to CHP, the amount of thermal energy produced is  
428 kept constant while the electric and thermal efficiencies differ from conventional technologies.  
429 The new CHP electric production (high temperature fuel cell) will be related to the old values  
430 (conventional technologies) to maintain the same annual trend, following the equation (Eq. 9).  
431 This  $E_{CHP}^{new}$  should replace the previous energy production of CHP in the balance of energy (Eq.  
432 1), which is accounted in the base load term.

$$433 \quad E_{CHP}^{new} = E_{CHP}^{old} \cdot \left( \frac{\eta_{th}}{\eta_{el}} \right)_{old} \cdot \left( \frac{\eta_{el}}{\eta_{th}} \right)_{new} \quad (\text{Eq. 9})$$

#### 434 **4. Results and discussion.**

435 Once presented the methodology to calculate those variable that determines the availability of  
436 energy surplus and the optimal PtG capacity to be installed, results may be obtained for each  
437 scenario and discussed.


##### 438 **4.1. Scenario 1: Back-up coverage through conventional power technologies**

439 As described in section 2.2, under *Scenario 1* the energy stored from PtG facilities will be used  
440 to cover the electrical load provided by back-up technologies. Therefore, the traditionally fossil-  
441 fuel fed back-up technologies are substituted by dispatchable energy technologies fed by  
442 renewable synthetic fuel gas. These dispatchable technologies will be gas turbine cycles and  
443 combined cycles fed by hydrogen or methane from PtG.

444 The results related to the PtG capacity, the energy stored as H<sub>2</sub> and the energy that cannot be  
445 harvested by the installed PtG capacity for different situations of installed capacities of wind and  
446 photovoltaic power are mapped in Figure 4. The situations analysed under this scenario varies  
447 from current situation in Spain (2016 as reference year) with regard to wind and photovoltaic  
448 installed power which corresponds to the values at point (0, 0) to an increase of the presence of  
449 both technologies up to a 50% of the theoretically maximum, point (0.5, 0.5). As stated in section  
450 1, current wind and photovoltaic installed power in Spain are 22.8 GW and 4.4 GW while the  
451 maximum installed power considered in Figure 4 are 157.87 GW and 35.45 GW, respectively.

452 The PtG installed capacity varies from 0.4 GW under current situation (0, 0) where energy  
453 surpluses are rarely found in the electric market as pointed out in Table 1 to 82.4 GW under the  
454 energy mix with the highest wind and photovoltaic penetration. These values are obtained from  
455 the duration curve built for each (x, y) energy mix situation.

456 The annual amount of energy stored as hydrogen calculated through (Eq. 5) ranges from 0 TWh  
 457 to 242 TWh which corresponds to near a 17% of the total primary energy consumed in the country  
 458 in 2016 [38].



459

460

Figure 4. (a) PtG capacity [GW]; (b) Energy stored as H<sub>2</sub> [TWh]; (c) Dumped energy [TWh].

461

462

463

Although energy stored as CH<sub>4</sub> is not presented, it can easily be calculated from the trends reported in Figure 4 (b) by multiplying by the efficiency of the methanation process as indicated in Eq. 6.

464

465

466

467

468

469

470

Part of the surplus energy will be lost due to the chosen size of the PtG system which will may not be able to absorb some of the production peaks. As an example, while chosen PtG capacity in the most extreme RES penetration situation is 82.4 GW, the maximum available power may reach 152 GW. This value lead to an annual energy availability up to 101.6 TWh (7% of the primary energy consumed in Spain in 2016) which could not be processed by PtG installed capacity. This energy could be stored by means of other storage technologies depending on the amount and hourly distribution.

471

472

473

474

475

476

The main target of this study is to find out the coverage of electrical demand by means of renewable energy which might be chemically stored through PtG systems and later used to generate electricity through conventional cycles but using a decarbonized fuel. The stored fuel presented in Figure 4 (b) can be reconverted back into electric energy to cover the back-up necessities by means of several technologies such as gas turbines, combined cycles and, only for hydrogen, fuel cells.

477

478

479

480


481

482

483

The conversion efficiency for the gas turbine cycles is assumed to be equal to 0.3, while in the case of combined cycles the value is 0.5. These efficiencies are lower than the generally accepted nominal values to consider the effect of part load functioning. While the use of gas turbine and combined cycles promotes an integration between the current productive fleet (24.91 GW current installed capacity of combined cycles in Spain [27]), to massively use fuel cell technologies would require a deep overhaul of the productive system. Thus, this last case (*case E*) will be analysed separately under *Scenario 3*.

484 The results related with values of  $\Phi$  are reported in Figure 5. Four combinations of stored  
 485 synthetic fuel and electricity generation technology are presented (a)  $\Phi$  for hydrogen and gas  
 486 turbine cycles; (b)  $\Phi$  for hydrogen and combined cycles; (c)  $\Phi$  for methane and gas turbine cycles;  
 487 (d)  $\Phi$  for methane and combined cycles. From these results, back-up technologies required to  
 488 cover electrical demand will be completely decarbonized by means of synthetic fuel generated  
 489 through PtG technologies in the ranges of 4.4-35.45 GW of photovoltaic and 39-76.8 GW of wind  
 490 power.



491

492 *Figure 5. (a)  $\Phi$  for H<sub>2</sub> and GT; (b)  $\Phi$  for H<sub>2</sub> and CCGT; (c)  $\Phi$  for CH<sub>4</sub> and GT; (d)  $\Phi$  for CH<sub>4</sub> and CCGT.*

493 The most favourable combination corresponds to the storage as hydrogen and the use of combined  
 494 cycles in the electricity generation, while the most penalized combination from an energetic point  
 495 of view corresponds to the storage as methane and the use of gas turbine cycles as electricity  
 496 production technology. In general, the effect of increased efficiency of combined cycles compared  
 497 to gas turbines and the penalty of CH<sub>4</sub> production are observed in Figure 5.


#### 498 **4.2. Scenario 2: Back-up and CHP coverage through conventional power technologies.**

499 The target established in *Scenario 2* is to cover electricity from back-up and CHP technologies  
 500 using the renewable synthetic gaseous fuel produced through PtG facilities. It can be assumed  
 501 that average electric and thermal efficiencies of CHP correspond to current values in the CHP  
 502 technologies of the country.

503 Using CHP electricity production data of the Spanish market between 2012-2016 [17], the  
 504 average electric efficiency of CHP in Spain is calculated to be 0.33, while the thermal efficiency  
 505 is around 0.47. If those figures remain unchanged, so does the ratio between thermal and electric  
 506 CHP production. This fact is highly relevant since the operation of CHP systems follows the  
 507 thermal requirements of the end users and while the electric output is regulated consequently.

508 Analogously to the previous scenario, the results obtained for  $\Phi$  under *Scenario 2* are reported in  
 509 Figure 6 for methane and hydrogen, and for the technologies gas turbine and combined cycle. It  
 510 is worth noting that these technologies are those used for the re-conversion of the fuel into  
 511 electricity when the PtG provides the electric storage service. They are not the technologies used  
 512 for the CHP, which, at this stage of the study, are characterized only by average electric and  
 513 thermal efficiencies.

514 Electricity back-up generation and conventional CHP technologies will be completely  
 515 decarbonized in the Spanish energy mix by means of using synthetic fuel generated through PtG  
 516 technologies when photovoltaic and wind power capacities increase in the country up to the  
 517 ranges of 4.4-35.45 GW and 71.4-109.2 GW, respectively.



518  
 519 *Figure 6. Case with the CHP which is powered by PtG-produced fuels (a)  $\Phi$  for  $H_2$  and GT for the electric storage;*  
 520 *(b)  $\Phi$  for  $H_2$  and CCGT for the electric storage; (c)  $\Phi$  for  $CH_4$  and GT for the electric storage; (d)  $\Phi$  for  $CH_4$  and*  
 521 *CCGT for the electric storage.*

522 Again, the situation with the lowest energy penalty corresponds to the storage as hydrogen and  
 523 the use of combined cycles in the electricity generation, while the most penalized combination  
 524 comes from the storage of methane and its conversion into electricity in gas turbine cycles.  
 525 Prospective studies point out that these values of photovoltaic installed capacity could be reached  
 526 in the country [12] while required wind installed capacities are far beyond the figures estimated  
 527 in these studies [11].


#### 528 **4.3. Scenario 3: Back-up and CHP coverage with FC technologies.**

529 *Scenario 3* introduces the possible modification of electricity generation technology to a more  
 530 efficient one such as high temperature fuel cells. This technology will be applied to (i) only back-  
 531 up technology and (ii) both back-up and CHP technology. Therefore, given the technology

532 considered in this scenario, only hydrogen is accounted as possible synthetic gaseous fuel  
 533 generated by PtG.

534 The high temperature fuel cells used in CHP characterized by an electric efficiency equal to 0.6  
 535 and a thermal efficiency equal to 0.2. Since these efficiencies are different from the current ones,  
 536 being equal the produced thermal energy, the CHP electric production must be re-scaled. CHP  
 537 electric production pattern is considered to remain unchanged, but the size of the power produced  
 538 in each hour is calculated using equation (Eq. 9). The new electric efficiency of CHP technology  
 539 modifies the production data, thus, for the same values of  $\gamma_w$  and  $\gamma_{pv}$ , a PtG capacity different from  
 540 *Scenarios 1 and 2* is expected. Apart from this, the workflow of this case is the same.

541 In Figure 7, results related with the PtG capacity, the amount of energy stored as H<sub>2</sub>, the values  
 542 assumed by  $\Phi$  with or without considering the quota of fuel needed to power the CHP are reported.



543  
 544 *Figure 7. (a) PtG capacity [GW]; (b) Energy stored as H<sub>2</sub> [TWh]; (c)  $\Phi$  for H<sub>2</sub> and FC, without considering the CHP*  
 545 *energy requirements; (d)  $\Phi$  for H<sub>2</sub> and FC considering the CHP energy requirements.*

546 PtG installed capacities obtained in *Scenario 3* vary from 6.9 GW for current installed capacities  
 547 of wind and photovoltaic power to 91.4 GW to the highest non-dispatchable installed capacities  
 548 considered in the calculations, (0.5, 0.5). When comparing Figure 7 (a) and 4 (a), it is clear that  
 549 the effects of the increased CHP electric production strongly influences the optimal PtG installed  
 550 capacity for low values of  $\gamma_w$  and  $\gamma_{pv}$ . Higher wind and photovoltaic installed capacities  
 551 overshadow the CHP production.


552 Figure 7 (b) indicates that the annual chemical energy stored in the form of hydrogen could vary  
 553 between 13.5 and 298.3 TWh which represent up to 20.7 % of the annual primary energy  
 554 consumption in the country. Furthermore, comparing Figure 7 (b) and 7 (c) it becomes clear that  
 555 the system does not need any electric storage service to decarbonize the participation of back-up

556 technologies. In fact, the stored energy and  $\Phi$  are equal what means that there is no residual load  
 557 to be covered by back-up technologies even for current RES installed capacities; i.e. the increased  
 558 CHP production is enough to cover the electric demand also for low values of  $\gamma_w$  and  $\gamma_{pv}$ .

559 In *Scenario 3*, the whole amount of fuel produced from PtG is used to power the CHP facilities.  
 560 To totally cover the CHP demand without hydrogen supplied from abroad, the quota of installed  
 561 RES must be pretty high, as showed in Figure 7 (d). RES combinations that fulfil the condition  
 562 established in *Scenario 3* ranges between (i) 4.4 GW of photovoltaic power and 114.6 GW of  
 563 wind power and (ii) 35.45 GW photovoltaic power and 93.0 GW of wind power.

#### 564 4.4. Potential denuclearization of the energy mix under SC1, SC2 and SC3

565 This section summarizes the results obtained when the previously described scenarios introduce  
 566 a modification in the electricity production data: not considering the contribution of the nuclear  
 567 plants. The trends illustrated in Figure 8 are similar to those reported in Figure 4, but the values  
 568 are systematically decreased because the duration curve is lowered by the absence of nuclear  
 569 production. Installed PtG capacity estimated to better manage surplus situations varies up to 76.2  
 570 GW for the highest RES penetration analyzed in the study while for non-denuclearized *SC1* and  
 571 *SC2* was calculated in 82.4 GW.




572  
 573 Figure 8. (a) PtG capacity [GW]; (b) Energy stored as H<sub>2</sub> [TWh]; (c) Energy dumped [TWh].

574  
 575 Under the denuclearized scenario, the annual amount of energy stored as hydrogen calculated  
 576 through (Eq. 5) ranges from 0 TWh to 204.6 TWh which corresponds to approximately a 14% of  
 577 the total primary energy consumed in the country. The amount of surplus energy which cannot be  
 578 handled by the installed PtG capacity along the year is 96.4 TWh. This amount should be stored  
 579 by means of a different storage technology.


580 Analogous consideration can be deduced from Figure 5 and Figure 9. The trends are similar but  
 581 the values of  $\gamma_w$  and  $\gamma_{pv}$  which make  $\Phi$  equal to zero are much higher than those reported for *SC1*.  
 582 Therefore, while retaining the current fossil-fueled CHP facilities, it would be possible to cover

583 the annual electrical demand after removing the nuclear energy from the Spanish energy mix, by  
 584 installing additional wind and photovoltaic power and applying PtG as electric storage. The share  
 585 of installed RES which fulfil this condition is rather high and its economic feasibility should be  
 586 analyzed. If methane is accounted as energy vector, the installed capacities of wind which fulfil  
 587 the *SCI* conditions ranges between 76.4 and 130.1 GW, for 66.5 and 4.4 GW of photovoltaic  
 588 power, respectively.



589  
 590 *Figure 9. (a)  $\Phi$  for H<sub>2</sub> and GT; (b)  $\Phi$  for H<sub>2</sub> and CCGT; (c)  $\Phi$  for CH<sub>4</sub> and GT; (d)  $\Phi$  for CH<sub>4</sub> and CCGT.*


591 Figure 10 reports the results of denuclearized *Scenario 2* in which the CHP is powered by the fuel  
 592 produced by the PtG. Again it would be still possible to fulfil the energy requirements of the  
 593 electric system with the adequate combination of wind, photovoltaic and PtG installed capacities.  
 594 Though, the RES capacity required is extremely high. In fact, for  $\gamma_w$  equal to 0.35 and  $\gamma_{pv}$  equal to  
 595 0.25 (one of the cases which satisfy the condition  $\Phi = 0$  for H<sub>2</sub> as stored fuel and CCGT as  
 596 electricity conversion technology) the installed capacity of photovoltaic and wind is  
 597 approximately equal to 154 GW, against a demand peak in the 2016 of around 40 GW. It is  
 598 therefore clear that the system would need to be greatly oversized when the electricity production  
 599 is entrusted only to RES.



600

601 *Figure 10. (a)  $\Phi$  for H<sub>2</sub> and GT for the electric storage; (b)  $\Phi$  for H<sub>2</sub> and CCGT for the electric storage; (c)  $\Phi$  for*  
 602 *CH<sub>4</sub> and GT for the electric storage; (d)  $\Phi$  for CH<sub>4</sub> and CCGT for the electric storage. Case with the CHP which is*  
 603 *powered by PtG-produced fuels.*

604 Lastly, the results for a denuclearized *Scenario 3* are reported in Figure 11. Under *SC3*, the energy  
 605 was only stored as hydrogen later converted into electric energy by means of fuel cells to cover  
 606 both types of demands: back-up technologies and CHP production. The PtG installed capacity  
 607 obtained following the proposed methodology is 84.6 GW (7 GW lower than the option which  
 608 include nuclear production).



609

610 *Figure 11. (a) PtG capacity [GW]; (b) Energy stored as H<sub>2</sub> [TWh]; (c)  $\Phi$  for H<sub>2</sub> and FC for the electric storage,*  
 611 *without considering the CHP energy requirements; (d)  $\Phi$  for H<sub>2</sub> and FC for the electric storage, considering the*  
 612 *CHP energy requirements.*

613 The main difference with the case that includes nuclear production (*SC3*) relies in the increase of  
 614 CHP electric production. Given the modification of the ratio between the electric and thermal

615 efficiency in CHP systems, the annual stored energy and  $\Phi$  (calculated without considering the  
616 CHP energy requirements) are not equal anymore. This behavior corresponds to negative values  
617 of  $BE_t$  (requirement of back-up technology) during the year.

618 In analogy with the previous cases, when fuel required by the CHP is considered into the  $\Phi$   
619 calculation (Figure 11 (d)), the values of  $\gamma_w$  and  $\gamma_{pv}$  required to cover the electric demand of the  
620 system by means of RES and PtG installed capacities, are pretty high. The increase in CHP  
621 production affects the duration curve shape, thus, this case is not the most burdensome from the  
622 load coverage point of view.

623 A detailed economic analysis to assess the levelized cost of electricity of variable renewable [39]  
624 under each of the proposed scenarios will complete the information required to understand which  
625 scenario is more reliable to be implemented in order to manage high wind and photovoltaic energy  
626 penetration in the Spanish electrical system. However, a thorough economic analysis of the  
627 proposed scenarios is beyond the scope of the study whose objective is the assessment of the  
628 technical feasibility.

## 629 **5. Conclusions.**

630 This study estimates the required installed power of wind, photovoltaic and PtG in Spain to  
631 decarbonize the electric system in the mid-large term. The analysis uses the maximum technical  
632 potential of installing new wind and PV power capacity as a measure of the feasibility of results.

633 The used methodology combines the definition of the balance of energy at time  $t$ ,  $BE_t$ , which  
634 shows the surplus energy situations (positive values) as well as the back-up requirements  
635 (negative values) every hour. This allows to properly size the PtG capacity by maximizing the  
636 amount of stored electricity at nominal load in the duration curve. Then, the whole system is  
637 solved by iterative calculations that make match the negative values of  $BE_t$ , with the recoverable  
638 electricity from the stored synthetic fuels, by modifying the installed capacity of wind and PV in  
639 each iteration.

640 Three scenarios are defined to reach different levels of decarbonization in the electricity system:  
641 (i) decarbonize only back-up technologies in electric generation, (ii) to additionally decarbonize  
642 industrial CHP in the country without replacing current CHP technologies and (iii) to decarbonize  
643 both back-up and CHP by considering fuel cells supplied with renewable  $H_2$  as implemented  
644 technology. All these scenarios may be covered by installing RES capacities below the technical  
645 potential estimated for the country. Installed PtG capacities between 80 and 90 GW will be  
646 required depending on the expected conditions of electrical coverage. This system allows to store  
647 an amount of surplus energy which is equivalent to 17% of total primary energy consumption in  
648 the country.

649 Finally, a potential denuclearization is approached. The same scenarios are studied without  
 650 accounting for nuclear power in the electrical generation system. The technical potential of wind  
 651 and photovoltaic power capacity to fulfil this condition is not surpassed but the required capacities  
 652 are extremely high and the economic feasibility of such system should be further analyzed.

653 **Nomenclature**

$C_i$	Installed capacity of technology $i$	[GW]
$E_{i,t}$	Electricity generated by technology $i$ at hour $t$	[TWh]
$D_t$	Electrical demand at hour $t$	[TWh]
$h_{nom}$	Number of hours working at nominal load	[h]
$SE_t$	Surplus energy at hour $t$	[TWh]
$\eta_{H2}$	Efficiency of electrolyzer	[-]
$\eta_{CH4}$	Efficiency of methanation process	[-]
$\eta_{GT}$	Thermal efficiency of gas turbine cycle	[-]
$\eta_{CCGT}$	Thermal efficiency of combined cycle	[-]
$\eta_{FC}$	Efficiency of fuel cell system	[-]
$\gamma_w$	Percentage of increased installed capacity of wind power	[-]
$\gamma_{pv}$	Percentage of increased installed capacity of PV power	[-]
$\Phi$	Difference between stored energy and required stored energy	[TWh]

654

655 **Subscripts**

$PtG$	Power to Gas
$PV$	Photovoltaic power
$st$	stored
$w$	Wind power

656

657 **Acronyms**

BL	Base load
CAES	Compressed air energy storage
CC	Combined cycle
CHP	Combined heat and power
ECS	Electrochemical storage
FC	Fuel cell
FES	Flywheels energy storage
GT	Gas turbine
HES	Hydrogen energy storage
ND	Non-dispatchable
PHS	Pumped hydroelectric storage
PtG	Power-to-Gas

RED	Renewable energy directive
RES	Renewable energy sources
TES	Thermal energy storage

658

## 659 **Acknowledgments**

660 Financial support for M.B. during his Ph.D. studies was co-funded by the Department of Industry  
 661 and Innovation of Diputación General de Aragón, and by the European Social Fund. The authors  
 662 would also like to acknowledge funding from Ministerio de Educación, Cultura y Deporte through  
 663 the program “José Castillejo”, CAS16/00065.

## 664 **References**

- 665 [1] European Parliament. Directive 2009/28/EC of the European Parliament and of the  
 666 Council of 23 April 2009. Off J Eur Union 2009;140:16–62.  
 667 doi:10.3000/17252555.L\_2009.140.eng.
- 668 [2] European Commission. Proposal for a directive of the European Parliament and of the  
 669 council on the promotion of the use of energy from renewable sources (recast)  
 670 2017;0382 (COD):1–116.
- 671 [3] International Energy Agency IEA. Energy Policies of IEA Countries: Spain 2015  
 672 Review. 2015.
- 673 [4] European Commission. Renewable energy progress report. Rep From Comm To Eur  
 674 Parliam Counc Eur Econ Soc Comm Comm Reg 2015;293:16.  
 675 doi:10.1017/CBO9781107415324.004.
- 676 [5] Schlachtberger DP, Brown T, Schramm S, Greiner M. The benefits of cooperation in a  
 677 highly renewable European electricity network. Energy 2017;134:469–81.  
 678 doi:10.1016/j.energy.2017.06.004.
- 679 [6] Aneke M, Wang M. Energy storage technologies and real life applications – A state of  
 680 the art review. Appl Energy 2016;179:350–77. doi:10.1016/j.apenergy.2016.06.097.
- 681 [7] Kirkerud JG, Bolkesjø TF, Trømborg E. Power-to-heat as a flexibility measure for  
 682 integration of renewable energy. Energy 2017;128:776–84.  
 683 doi:10.1016/j.energy.2017.03.153.
- 684 [8] Kheradmand-Khanekhdani H, Gitizadeh M. Well-being analysis of distribution network  
 685 in the presence of electric vehicles. Energy 2018;155:610–9.  
 686 doi:10.1016/j.energy.2018.04.164.
- 687 [9] Götz M, Lefebvre J, Mörs F, McDaniel Koch A, Graf F, Bajohr S, et al. Renewable  
 688 Power-to-Gas: A technological and economic review. Renew Energy 2016;85:1371–90.  
 689 doi:10.1016/j.renene.2015.07.066.
- 690 [10] Connolly D. Heat Roadmap Europe: Quantitative comparison between the electricity,  
 691 heating, and cooling sectors for different European countries. Energy 2017;139:580–93.  
 692 doi:10.1016/j.energy.2017.07.037.
- 693 [11] EWEA. Wind energy scenarios for 2030. Ewea 2015:1–8.
- 694 [12] Hoefnagels R, Junginger M, Panzer C, Resch G, Held A. Long Term Potentials and  
 695 Costs of RES Part I: Potentials, Diffusion and Technological learning. RE-Shaping D10  
 696 Report 2011:99.

- 697 [13] IDAE. Informe de sostenibilidad ambiental del Plan de Energías Renovables 2011-2020.  
698 2011.
- 699 [14] Aymami, J; García, A; Lacave, O; Lledó, L; Mayo, M; Parés S. Análisis del recurso.  
700 Estudio técnico PER 2011-2020. Atlas eólico de España 2011.
- 701 [15] International Energy Agency IEA. Potential for building integrated photovoltaics. IEA-  
702 PVPS Task 2002;2002:2-4.
- 703 [16] MAPAMA. Factores de emisión: registro de huella de carbono, compensación y  
704 proyectos de absorción de dióxido de carbono. 2017.
- 705 [17] Red Eléctrica Española. ESIOS-REE Transparency Report. 2017.
- 706 [18] MINETUR. Planificación energética indicativa según lo dispuesto en la Ley 2 / 2011 , de  
707 4 de marzo , de Economía Sostenible. 2011.
- 708 [19] Club Español De La Energía. Balance Energético de 2016 y Perspectivas para 2017.  
709 2016.
- 710 [20] Qadrdan M, Abeysekera M, Chaudry M, Wu J JN. Role of power-to-gas in an integrated  
711 gas and electricity system in Great Britain. *Int J Hydrog Energy* 2015;40:63-75.  
712 doi:doi:10.1016/j.ijhydene.2015.03.004.
- 713 [21] Bailera M, Lisbona P. Energy storage in Spain: forecasting electricity excess and  
714 assessment of Power-to-Gas potential up to 2050. *Energy* 2017.  
715 doi:10.1016/j.energy.2017.11.069.
- 716 [22] Varone A FM. Power to liquid and power to gas: An option for the German  
717 Energiewende. *Renew Sustain Energy Rev* 2015;45:207-18.  
718 doi:doi:10.1016/j.rser.2015.01.049.
- 719 [23] Dominković DF, Dobravec V, Jiang Y, Nielsen PS, Krajačić G. Modelling smart energy  
720 systems in tropical regions. *Energy* 2018;155:592-609.  
721 doi:10.1016/j.energy.2018.05.007.
- 722 [24] International Energy Agency IEA. *Energy Technology Perspectives 2017*. IEA; 2017.  
723 doi:10.1787/energy\_tech-2017-en.
- 724 [25] Guandalini G, Robinius M, Grube T, Campanari S, Stolten D. Long-term power-to-gas  
725 potential from wind and solar power: A country analysis for Italy. *Int J Hydrogen Energy*  
726 2017;1-18. doi:10.1016/j.ijhydene.2017.03.081.
- 727 [26] Colbertaldo P, Guandalini G, Campanari S. Modelling the integrated power and  
728 transport energy system: The role of power-to-gas and hydrogen in long-term scenarios  
729 for Italy. *Energy* 2018;154:592-601. doi:10.1016/j.energy.2018.04.089.
- 730 [27] Red Eléctrica Española. *The Spanish Electricity System - Preliminary report 2017*. 2018.
- 731 [28] European Environment Agency. *Overview of electricity production and use in Europe*.  
732 2015.
- 733 [29] UNESA. *Prospectiva de generación eléctrica 2030*. 2007.
- 734 [30] Ministerio de Industria Energía y Turismo. Orden IET/2101/2014, de 3 de noviembre,  
735 por la que se concede la renovación de la autorización de explotación de la central  
736 nuclear Trillo I. 2014.
- 737 [31] Lechtenböhmer S, Nilsson LJ, Åhman M, Schneider C. Decarbonising the energy  
738 intensive basic materials industry through electrification – Implications for future EU  
739 electricity demand. *Energy* 2016;115:1623-31. doi:10.1016/j.energy.2016.07.110.

- 740 [32] Bailera M, Lisbona P. Energy storage in Spain: Forecasting electricity excess and  
741 assessment of power-to-gas potential up to 2050. *Energy* 2018;143.  
742 doi:10.1016/j.energy.2017.11.069.
- 743 [33] Montoya FG, Aguilera MJ, Manzano-Agugliaro F. Renewable energy production in  
744 Spain: A review. *Renew Sustain Energy Rev* 2014;33:509–31.  
745 doi:10.1016/j.rser.2014.01.091.
- 746 [34] International Energy Agency IEA. Technology Roadmap Solar Thermal Electricity.  
747 2014. doi:10.1007/SpringerReference\_7300.
- 748 [35] Koponen J. Review of water electrolysis technologies and design of renewable hydrogen  
749 production systems. Lappeenranta University of Technology, 2015.
- 750 [36] Miguel C V., Soria MA, Mendes A, Madeira LM. A sorptive reactor for CO<sub>2</sub> capture and  
751 conversion to renewable methane. *Chem Eng J* 2017;322:590–602.  
752 doi:10.1016/j.cej.2017.04.024.
- 753 [37] Ghaib K, Ben-Fares FZ. Power-to-Methane: A state-of-the-art review. *Renew Sustain*  
754 *Energy Rev* 2018;81:433–46. doi:10.1016/j.rser.2017.08.004.
- 755 [38] MINETUR. La Energía en España 2016. 2017.
- 756 [39] Reichenberg L, Hedenus F, Odenberger M, Johnsson F. The marginal system LCOE of  
757 variable renewables – Evaluating high penetration levels of wind and solar in Europe.  
758 *Energy* 2018;152:914–24. doi:10.1016/j.energy.2018.02.061.
- 759